

## ADDENDUM NO 1

TO THE PLANS AND SPECIFICATIONS FOR:  
ROOF REPLACEMENT 2016  
CITY OF MORaine MUNICIPAL BUILDING  
MORaine, OHIO  
8 September 2016

**TO ALL BIDDERS:**

This addendum supplements, modifies and amends the original plans and contract specifications and shall become part of the bidding contract documents for the referenced project.

This addendum is intended to clarify or correct parts of the contract documents. Any questions shall be directed, in writing to

RDA Group, Inc.

7945 Washington Woods Drive

Dayton, OH 45459

**Item 1:** Project Access: Upper roof area D is only accessible via the sloped metal roof. There is not interior access.

**Item 2:** Sheet A.1.1, Roof Plan: Clarification: Delete erroneous note: "Remove existing, install new roof drawings in existing locations" Replace with note: "Install new roof drain inserts at all existing roof drain locations. Install any/all applicable components to make roof drains fully operational". This is applicable for Roof Area A and E.

**Item 3:** Sheet A.1.1, Roof Plan: Clarification: Delete erroneous note: "Existing expansion joint to remain" [2 notations]; Replace with note: "Remove existing, install new expansion joint". Detail E is applicable for the entire length of the expansion joint between Roof Area A-B and Roof Area E-F.

This addendum must be acknowledged on the bid form as received and considered in their bid.

END OF ADDENDUM 1